

NOTICE INVITING TENDER

No. Accts/Part/436/

Dated Guwahati the th September, 2021

Sealed Tender bids affixing non refundable court fee stamp of Rs.8.25 (Rupees eight & paise twenty five only) are invited by the undersigned from the eligible vendor/firm/company/contractor for supply, installation and commissioning of "Lightning Arrester & Earthing protection system" in the 4(Four) Storeyed building of the office of the Chief Inspector of Factories, Assam, NPS International School Lane, Betkuchi, Lohra, Guwahati-781040.


Aspiring Bidder may obtain the detailed "Technical Specification along with Terms & Conditions" from 01-10-2021 to 08-10-2021 during working hours from the office of Chief Inspector of Factories, Assam, NPS International School Lane, Betkuchi, Lohra, Guwahati-781040, or download the same from this office's website www.ciflabour.assam.gov.in

The last date of submission of bid is 3 P.M on 08-10-2021 and shall be opened in the office of the undersigned at 3-30 P.M on the same day in presence of the representatives of the Bidders if they desire so.

In case, it happens to be a Govt. Holiday, bids will be accepted till 3.00 P.M of the next working day and will be opened at 3.30 P.M on the same day.

The bidder may visit/examine the said office premise on any working day during office hours for purpose assessment of the scope of the work before submitting their bids. No claim whatsoever will be entertained later on.

The undersigned reserves the right to accept or reject in part or full, any or all the offers without assigning any reason thereof.




Chief Inspector of Factories, Assam
NPS International School Lane, Betkuchi
Lohra, Guwahati-40

Memo No. Accts/Part/436/ **3660-61**

Dated Guwahati the **30**th September, 2021

Copy To:

1. Website
2. Office Notice Board



Chief Inspector of Factories, Assam
NPS International School Lane, Betkuchi
Lohra, Guwahati-40

Technical Specifications

SI No.	Technical Description	Quantity	Remarks
1.	Early Streamer Emission (ESE) L.A. Supply & Installation of ESE Lightning protection system for cover coverage of 60 meter radius at level-I.G.I pole 2.0 mtr.(H).Down conductor 70 sq.mm aluminium as required with the system. Six digit Lightning strike counter with IP 65 stand. Earthing Bus bar-2 nos. All other required accessories as specified in drawing, Labour cost & transportation etc	01(one) Set	Product catalogue, CPRI test certificate Compulsory for ESE device.
2.	Surge Protection Device (SPD) Surge protection Device (SPD) for AC Line Type-1+2 Protection based on MOV+ GDT Technology. Data Line Surge Protection as required in existing server system.	As required	Product catalogue & installation diagram compulsory
3.	Ground Earthing Solution Supply, installation & testing of Copper Bonded Chemical earthing electrode 80 mm 2.0 mtr.(L) heavy duty, Construction of earth Pit chamber with plastering, size:300 mmX 300 mm with C.I. inspection cover plate, earth pit digging upto 2.0.mtr & refilling with ERIC & Clay soil as back fill, as specified in drawing.	08(eight) Sets	Product catalogue, CPRI test certificate Compulsory for Earth Electrode & ERIC.

sd/-
Chief Inspector of Factories, Assam,
Betkuchi, Lohra, Guwahati-40

Terms and Conditions:

1. The Bidder should deposit a DD for 2% of the quoted amount towards the earnest money (EMD) drawn in favour of the Chief Inspector of factories, Assam, Guwahati-40. EMD of all unsuccessful bidders will be returned after finalization of the tender. No interest will be payable on the EMD.
2. The Bidder should have valid Electrical Contractor License issued by Electrical Licensing Board, Govt. of Assam for supply, installation and commissioning of Lighting Arrester & earthing protection.
3. The Bidder should submit photocopies of Trade Licence, GST Registration No. & PAN Card.
4. The contractor should have at least two similar type of work execution experience in last three years.
5. The ESE Lighting Arrester & Earthing Electrodes should be guaranteed for 15(fifteen) years of service life.
6. All the relevant drawing and test from CPRI & other authority to be submitted along with quotation.
7. The Bidder should submit their Bid in sealed envelope superscribing **“Quotation for supply, installation and commissioning of Lightning Arrester & Earthing protection System.”**
8. The price should be quoted in both figures & words and should remain valid till 31.03.2022
9. Necessary Tax will be deducted from the bill as source at per existing Rule of Govt.
10. Payment of the bill is subjected to release of fund by the Govt.

sd/-

Chief Inspector of Factories, Assam,
Betkuchi, Lohra, Guwahati-40